



Work Order - Backup or Blockage Call

Hull Wastewater

Work Order Information

Date:	06/10/2015	Type:	Corrective Maintenance	Status:	In Process
Asset	22 - WW - sewers/pipes/force mains	Priority:	Normal	Reason:	Dirt / Debris

Description of Issue

Description: 14 Vautrinot Ave

Notes: Request by PSC - leak in road

Actions Taken

Staff: Aram Varjarbedian

Service: Inspect manholes and camera used. Could not snake through from upstream manhole. Got to within 25 feet of leak snaking camera upstream. Upstream manhole of leak had a lot of debris and evidence of manhole deterioration. Report findings to PSC.

Photos



Upstream manhole



Blockage in upstream manhole